

Report No.: 32.07315 EMMA Track Light

Test Time: 2023-09-09 15:04

Luminaire Property

Luminaire Category: Bridgelux V13C 3000K CRI90

Voltage: 220.7 V

Current: 0.108 A

Power: 23.40 W

Power Factor: 0.973

Photometric Results

CIE Class: Direct

Measurement Flux: 2963.1 lm

Downward Ratio: 100%

Horizontal Diffuse Angle(50%): H40.5

Vertical Diffuse Angle(50%): V40.5

Luminaire Efficacy Rating (LER): 127

Max. Intensity: 6483.34 cd

Total Rated Lamp Lumens: 2963.1 lm

Efficiency: 100%

Upward Ratio: 0%


Central Intensity: 6483.33 cd

Pos of Max. Intensity: H0 V0



Picture Of Luminaire



Luminous Intensity Distribution Curve



Luminous Intensity Distribution Curve




Unit: cd

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:5.0
Test Device: CHL-6E
Distance: 3.000 m
Humidity:
Inspector:

Isocandela (rectangle)



Imax (100%): 6483 cd

(10%): 648 cd	(16%): 1037 cd
(25%): 1621 cd	(40%): 2593 cd
(63%): 4084 cd	(100%): 6483 cd

C Plane (°):0.0-180.0: 180.0

Test Lab:

Test Type: TYPE C

Temperature:

Operator:

Gamma Plane (°):0.0-90.0:5.0


Test Device: CHL-6E

Distance: 3.000 m

Humidity:

Inspector:

IsoLux Plot




Mounting Height: 10m		Max Lux(100%): 65 lx	
(1%):	1 lx	(2%):	1 lx
(5%):	3 lx	(10%):	6 lx
(20%):	13 lx	(50%):	32 lx
(100%):	65 lx		


C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:5.0
Test Device: CHL-6E
Distance: 3.000 m
Humidity:
Inspector:

Illuminance at a Distance



Vertical IsoLux Plot




Lowest(m): 1m Highest(m): 11 Max Lux: 6483

(1%): 65 lx	(2%): 130 lx
(5%): 324 lx	(10%): 648 lx
(20%): 1297 lx	(50%): 3242 lx
(100%): 6483 lx	

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:5.0
Test Device: CHL-6E
Distance: 3.000 m
Humidity:
Inspector:

The average illuminance effective figure



C Plane (°): 0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°): 0.0-90.0: 5.0
Test Device: CHL-6E
Distance: 3.000 m
Humidity:
Inspector:

Gamma Plane (°):0.0-90.0:5.0
Test Device: CHL-6E
Distance: 3.000 m
Humidity:
Inspector:

Unit: cd

Gamma Plane (°):0.0-90.0:5.0
Test Device: CHL-6E
Distance: 3.000 m
Humidity:
Inspector: