

Report No.: 52.08011 ECO Downlight

Test Time: 2023-10-06 16:07

Luminaire Property

Luminaire Category: Bridgelux V10A F90 3000K CRI90

Voltage: 224.1 V

Current: 0.091 A

Power: 19.60 W

Power Factor: 0.959

Photometric Results

CIE Class: Direct

Measurement Flux: 2185.1 lm

Downward Ratio: 100%

Horizontal Diffuse Angle(50%): H36.4

Vertical Diffuse Angle(50%): V36.4

Luminaire Efficacy Rating (LER): 111

Max. Intensity: 5638.48 cd

Total Rated Lamp Lumens: 2185.1 lm


Efficiency: 100%

Upward Ratio: 0%


Central Intensity: 5638.47 cd

Pos of Max. Intensity: H0 V0

Picture Of Luminaire



Luminous Intensity Distribution Curve



— C0-C180 — C90-C270 — G0

C Plane (°):0.0-180.0: 180.0

Test Lab:

Test Type: TYPE C

Temperature:

Operator:

Gamma Plane (°):0.0-90.0:5.0



Test Device: CHL-6E

Distance: 3.000 m

Humidity:

Inspector:

Luminous Intensity Distribution Curve




Unit: cd

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:5.0
Test Device: CHL-6E
Distance: 3.000 m
Humidity:
Inspector:

Isocandela (rectangle)



Imax (100%): 5638 cd

(10%): 564 cd	(16%): 902 cd
(25%): 1410 cd	(40%): 2255 cd
(63%): 3552 cd	(100%): 5638 cd

C Plane (°):0.0-180.0: 180.0

Test Lab:

Test Type: TYPE C

Temperature:

Operator:

Gamma Plane (°):0.0-90.0:5.0


Test Device: CHL-6E

Distance: 3.000 m

Humidity:

Inspector:

IsoLux Plot



Mounting Height: 10m Max Lux(100%): 56 lx

(1%):	1 lx	(2%):	1 lx
(5%):	3 lx	(10%):	6 lx
(20%):	11 lx	(50%):	28 lx
(100%):	56 lx		

C Plane (°):0.0-180.0: 180.0

Test Lab:

Test Type: TYPE C

Temperature:

Operator:

Gamma Plane (°):0.0-90.0:5.0


Test Device: CHL-6E

Distance: 3.000 m


Humidity:

Inspector:

Illuminance at a Distance



Vertical IsoLux Plot




Lowest(m): 1m Highest(m): 11 Max Lux: 5638

(1%): 56 lx	(2%): 113 lx
(5%): 282 lx	(10%): 564 lx
(20%): 1128 lx	(50%): 2819 lx
(100%): 5638 lx	

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:5.0
Test Device: CHL-6E
Distance: 3.000 m
Humidity:
Inspector:

The average illuminance effective figure



C Plane (°): 0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°): 0.0-90.0: 5.0
Test Device: CHL-6E
Distance: 3.000 m
Humidity:
Inspector:

Gamma Plane (°):0.0-90.0:5.0
Test Device: CHL-6E
Distance: 3.000 m
Humidity:
Inspector:

Unit: cd

Gamma Plane (°):0.0-90.0:5.0
Test Device: CHL-6E
Distance: 3.000 m
Humidity:
Inspector: